

**CENTRAL TEXAS WATER SUPPLY CORPORATION
DROUGHT CONTINGENCY**

REGARDING STILLHOUSE HOLLOW LAKE RESERVOIR LEVELS

CTWSC Drought Reponse Stage	Triggering Criteria	Target	CTWSC Management Practice
Stage 1 Mild Conditions LAKE LEVEL-605 FEET	Reservoir levels at 60 % of capacity	Raise public and customer awareness of raw water supply, demand and reservoir conditions	Initiate communication with wholesale customers encourage efficient use of water.
Stage 2 Moderate Conditions LAKE LEVEL-600 FEET	Reservoir levels at 50 % of capacity	Reduce raw water diversions from reservoir by 10%	Begin reductions in water supply to wholesale customers. Notify TCEQ.
Stage 3 Severe Conditions LAKE LEVEL-595 FEET	Reservoir levels at 40 % of capacity	Reduce raw water diversions from reservoir by 50%	Begin additional water reductions to wholesale customers and implement water rate surcharges for excessive use of water. Notify TCEQ. Surcharge of 1.5 % of current Board set rate.
Stage 4 Emergency Conditions LAKE LEVEL-590 FEET	Reservoir below 30 % or at critical levels of capacity	Discontinue reservoir raw water diversions	Intitate emergency procedures. Notify TCEQ

BRAZOS RIVER AUTHORITY-LAKE LEVEL 584 FEET	30% OF TOTAL LAKE CAPACITY
---	---------------------------------------